

**GOVT. OF ASSAM**  
**SUB-DIVISIONAL LEVEL LABORATORY, MORAN**  
**PUBLIC HEALTH ENGINEERING DEPARTMENT**  
Moran Sub-Division, Dist.:- Dibrugarh, Assam, 785675  
Email ID: sdllmoran8@gmail.com

No.:- AEE/PHE/MRN/LAB-1/2024-25/.....<sup>44</sup>.....

Date:-.....<sup>31/06/2024</sup>.....

**WATER ANALYSIS REPORT**

Sample ID	SDLL/MRN/2024-25/466		
Issued to	Down Town Gurukul	Sample Received Date	27/05/2024
Pin point	Down Town Gurukul Tap 4	Block	Mahmora
GP	Amguri	Town	Moranhat
Type of Source	Treated Water	Source Installed	Self
Quantity	1000ml	Sample Collected On	27/05/2024
Date of Analysis Started	27/05/2024	Date of Analysis Completed	29/05/2024

Sl. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence of better alternate source)	
<b>PHYSICAL TEST</b>						
1	pH	IS: 3025: Part 11	6.74	6.5 - 8.5	No relaxation	pH Units
2	TDS	IS: 3025: Part 16	129	500	2000	mg/L
3	Turbidity	IS: 3025: Part 10	1.3	1	5	NTU
4	Colour	IS: 3025: Part 4	10	5	15	Hazen
5	Odour	IS: 3025: Part 5	A	Agreeable	Agreeable	
6	Taste	IS: 3025: Part 8	A	Agreeable	Agreeable	
<b>CHEMICAL TEST</b>						
7	Chloride	IS: 3025: Part 32	14.18	250	1000	mg/L
8	Total Hardness	IS: 3025: Part 21	122	200	600	mg/L
9	Total Alkalinity	IS: 3025: Part 23	80	200	600	mg/L
10	Calcium	IS: 3025: Part 40	32.06	75	200	mg/L
11	Magnesium	APHA-3500- Mg B	10.2	30	100	mg/L
12	Iron	APHA-3500-Fe B	0.39	1	No Relaxation	mg/L
13	Residual Chlorine	APHA 4500-Cl B	0	0.2	1	mg/L
<b>BACTERIOLOGICAL TEST</b>						
14	Bacteria	H <sub>2</sub> S Vial	Absent	No Relaxation	No Relaxation	

Remarks:- Analysed parameters were found within the permissible limit.

*Butta*  
Asst. Chemist  
Moran SDLL

*[Signature]*  
Lab In-charge  
Moran SDLL

\*\*\*\*\*END OF THE REPORT\*\*\*\*\*





**GOVT. OF ASSAM**  
**OFFICE OF THE JOINT DIRECTOR OF HEALTH**  
**SERVICES::CHARAIDEO**


No. Jt.DHS/CRD /Hygiene/2024/ 383

Dated Charaideo the 12/6/2024

This is to certify that **DOWN TOWN GURUKUL SCHOOL** of MORANHAT SITUATED AT 2 NO. SARUPATHER, ABHAYAPUR ,MORAN RAJGARH ROAD. DIST. CHARAIDEO, ASSAM, owned by **DOWN TOWN CHARITY TRUST** was inspected by Sri.Ghanakanta Chutia, Sanitary Inspector under the establishment of Jt.DHS, Charaideo on 12/06/2024 and found satisfactory from hygienic and sanitary point of view during time of inspection.


Signature of owner

  
Joint Director of Health Services

Charaideo  
Joint Director of Health Services  
Charaideo


**N.B. This certificate will be valid up to one year on the basis of good hygienic condition only.**